

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR
CORPORATION OF HARPERS FERRY, WV3301912**

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 5/1/2022 and 5/31/2022, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
3A, MONITORING, ROUTINE, MINOR (RTCR) Valid Compliance Total Coliform Sample(s) Not Received	5/1/2022 to 5/31/2022

What happened? What is being done? (Describe corrective action)

Distractions due to a plant rebuild led to a missed bacteriological sample with associated chlorine tests. Standard operating procedure has been revised to add all BacT sample due dates to the plant's operating calendar no later than Jan 31 for upcoming year with automatic reminders set to notify chief operator.

For more information, please contact Christian Styer, chief operator at 304.535.6555
(Contact name) (Phone number)

Or Harpers Ferry Water Works / PO Box 217 / Harpers Ferry, WV 25425

(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **CORPORATION OF HARPERS FERRY**

State Water System ID #: WV3301912

Date Distributed: 1 March, 2023

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

CORPORATION OF HARPERS FERRY, WV3301912

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 5/1/2022 and 5/31/2022, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Missing Required Chlorine Residual Associated With a Bacteriological Sample	5/1/2022 to 5/31/2022

What happened? What is being done? (Describe corrective action)

Distractions due to a plant rebuild led to a missed bacteriological sample with associated chlorine tests. Standard operating procedure has been revised to add all BacT sample due dates to the plant's operating calendar no later than Jan. 31 for upcoming year with automatic reminders set to notify chief operator.

For more information, please contact Christian Styer, chief operator at 304.535.6555
(Contact name) (Phone number)
Or Harpers Ferry Water Works / PO Box 217 / Harpers Ferry, WV 25425
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **CORPORATION OF HARPERS FERRY**

State Water System ID #: WV3301912

Date Distributed: 1 March, 2023

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

CORPORATION OF HARPERS FERRY, WV3301912

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 5/1/2022 and 5/31/2022, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
36, MONITORING, RTN/RPT MAJOR (SWTR-FILTER) CHLORINE Missing Required Chlorine Residual Associated With a Bacteriological Sample	5/1/2022 to 5/31/2022

What happened? What is being done? (Describe corrective action)

Distractions due to a plant rebuild led to a missed bacteriological sample with associated chlorine tests. Standard operating procedure has been revised to add all BacT sample due dates to the plant's operating calendar no later than Jan. 31 for upcoming year with automatic reminders set to notify chief operator.

For more information, please contact Christian Styer, chief operator at 304.535.6555
(Contact name) (Phone number)

Or Harpers Ferry Water Works / PO Box 217 / Harpers Ferry, WV 25425
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **CORPORATION OF HARPERS FERRY**

State Water System ID #: WV3301912

Date Distributed: 1 March, 2023